

The minutes of the pre-bid meeting are tabulated below:

Our Tenders Specifications	Bidders Query	Our Reply
<p>Car door / landing door of size 700 (w) x 2000 (h) mm automatic power operated center opening sliding doors with transparent laminated toughened glass of 11 mm thickness to be fitted</p>	<p>M/s Kone : Not possible. Alternatively suggested for provision of vision glass of size 85 mm x 150 mm only for both car and landing doors M/s. TRIO & M/s. Emperor Stainless framed glass doors can be considered. The size of entrance door is 700 mm (w) x 2000 mm (h). The size of each door shall be 350 mm (w) x 2000 mm (h). The size of glass panel suggested by the tenderor for each door 200 mm (w) x 1800 mm (h) with SS frame work.</p>	<p>SS Framed glass doors (the toughened glass of 10 mm should be enclosed by SS 304 frame from all side of glass) shall be considered instead of full glass doors both for car and landings as mentioned in the BOQ.</p>
<p>Glass thickness Toughened glass of 11 mm thickness</p>	<p>The thickness of glass panel should be 8 mm toughened glass as against the tender requirement of 11 mm</p>	<p>Thickness of toughened glass will be 10 mm</p>
<p>Car Ceiling: SS 304 with white acrylic sheet</p>	<p>Suggested SS 304 Finish with LED luminaires since provision of acrylic sheet is an outdated one</p>	<p>Since SS false ceiling with acrylic cover is considered to be an outdated model, SS 304 false ceiling complete with LED luminaires may be considered for acceptance.</p>
<p>Side Panels SS 304 width 1.5 mm thick & skirting</p>	<p>Suggested for 1.2 mm SS 304 grade for side wall panels, doors frame and ceiling</p>	<p>1.2 mm thick SS 304 may be considered instead of 1.5 mm mentioned in the tender specifications.</p>

