

Date: 07.05.2020

Clarifications/Amendments to the Pre-bid Queries Ref: CO/ITD/2562/R1/2020-21 dated 28/04/2020 - Supply, Installation, Commissioning and Maintenance of 2 Nos. of 30 KVA UPS.

1. Clarification/Amendment

S.No	RFP Clause	Query Raised	Response to Query/Remarks from Bank
1.	<p>Page No. 19- Part-I- Specification of 30 KVA UPS with Batteries- (2 hours backup)</p> <p>S.No. 2.1: Technology: Type of UPS: Double Conversion Online UPS with inbuilt input side Isolation Transformer.</p> <p>S.No. 14: Isolation Transformer: Inbuilt Output isolation transformer</p>	<p>In the Specification, as per S.No.2.1, it is inbuilt input isolation transformer which we have considered.</p> <p>S.no.14 is contradict with this point and asking for Inbuilt output isolation transformer.</p>	<p>There is a typo error in S.No. 2.1.</p> <p>Amended clause is as mentioned below:</p> <p>Technology: Type of UPS: Double Conversion Online UPS with inbuilt output side Isolation Transformer.</p>
2.	<p>Page No. 14: Other Terms and Conditions: Point No. 2: Either OEM or authorized Agents (SI) on behalf of OEM can bid in the tender but not both.</p>	<p>Kindly confirm whether Resllers can participate or only Manufactures.</p>	<p>Only manufactures of UPS can participate in the tender.</p>

