

Sl.No	Description	Bidder Query	As per Tender (Technical Bid)		Bank's Reply	
			Clause	Page		
02	Price Bid (Part-2)	For capacity below 24HP, i.e. for 16 & 14 HP - only single inverter is available in all the makes except make of M/s. Toshiba instead of double inverters.	1.a, b, c	2 & 3	Outdoor Unit (ODU) of 24 HP cooling capacity (fully inverter type) with suitable electrical & refrigerant line interconnections, With Minimum 2 Inverter Compressors with two fans for better efficiency initial charge of refrigerant R 410 A and ready for use with single point electrical supply & refrigerant suction / liquid line tapping, etc complete as required.	Tender conditions holds good.
03	Price Bid (Part-2)	Instead of 24 HP shall we provide 2 modules viz., 2nos x 14HP etc.,	1.a	2	Outdoor Unit (ODU) of 24 HP cooling capacity (fully inverter type) with suitable electrical & refrigerant line interconnections, With Minimum 2 Inverter Compressors with two fans for better efficiency initial charge of refrigerant R 410 A and ready for use with single point electrical supply & refrigerant suction / liquid line tapping, etc complete as required.	Tender condition holds good. However, total capacity shall not be varied due to combination i. e. it should not be less than the tender capacity. (Tender Ref.: Technical Bid (part-1) Sl. No. 4 & 5, page no. 48 of 63) .i.e vendor may provide additional capacity but we will consider as 24HP Only.



Sl.No	Description	Bidder Query	As per Tender (Technical Bid)		Bank's Reply	
			Clause	Page		
04	Price Bid (Part- 2)	While removing the old AC units, breaking of walls / civil foundation etc is required, rectifications of broken wall are in whose scope?	24	11	As per item no. 24, pg no 11 of Price Bid (Part – 2) Civil works on account of dismantling of AC units (but not limited to the items in Sl. No. 24) viz., plastering of broken area, removal of debris from the site / disposing of the same outside the IMAGGE campus complying to the local laws etc., and rectification civil & carpentry works / painting / transportation etc.,	It is already considered as per item no. 24, pg no 11 of Price Bid (Part – 2). Existing AHU's need to be dismantled and take out as scrap. Breaking of walls will not be permitted.
05	Price Bid (Part- 2)	dismantling of AC units	24	11	Civil works on account of dismantling of AC units (but not limited to the items in Sl. No. 24) viz., plastering of broken area, removal of debris from the site / disposing of the same outside the IMAGGE campus complying to the local laws etc., and rectification civil & carpentry works / painting / transportation etc.,	Read it as: Civil works on account of dismantling of AC units (but not limited to the items in Sl. No. 25) viz., plastering of broken area, removal of debris from the site / disposing of the same outside the IMAGGE campus complying to the local laws etc., and rectification civil & carpentry works / painting / transportation etc.,

