

इंडियन बैंक



Indian Bank

इलाहाबाद

ALLAHABAD

**NOTICE FOR INVITING QUOTATIONS FOR RATE CONTRACT FOR SUPPLY AND INSTALLATION OF
FIRE EXTINGUISHER IN BRANCHES/ OFFICES/ ATMs UNDER RAIPUR ZONE OF BANK
SITUATED IN STATE OF CHHATTISGARH**

Indian Bank, Zonal Office, Raipur invites quotations for notice for inviting quotations for rate contract for supply and installation of fire extinguisher in branches/ offices/ ATMS under Raipur zone of bank situated in state of Chhattisgarh.

You are requested to submit the same in a sealed envelope super scribing as **“QUOTATION FOR RATE CONTRACT FOR SUPPLY AND INSTALLATION OF FIRE EXTINGUISHER”** as per attached format.

Please Note that:

- (1) Quotation may be dropped in the box kept at **Zonal Office, Indian Bank, Bachhawat Complex, New Shanti Nagar, Raipur, Chhattisgarh 492005.**
- (2) Last date for submission of quotation is **09 Feb 2022 by 01:00 PM.**
- (3) Award of rate contract will be for one year which may be extended for another one year(s) if both party agrees.
- (4) Bids will be opened on 09 Feb 2022 at 03.00 PM by the Bank's committee in front of the bidders who wished to be present during tender opening.
- (5) The firm submitting quotations must have official set up in Chhattisgarh state and service engineers across Chhattisgarh state.
- (6) The firm must have the past experience of repair & Maintenance of above machines in banking sector, documentary proof i.e. Purchase Order/Service Order shall be submitted along with the quotation.
- (7) Bank has the right to amend/postpone/cancellation of the process.
- (8) All entries in the quotation should be legible and filled correctly. If the space for furnishing information is insufficient, a separate sheet duly signed by the authorized signatory may be attached.

Date: 22 Jan 2022

COMMERCIAL BID

Rate for New Fire Extinguishers

Sl.No.	Description	Capacity	Qty	Unit Price including transportation, labour cost etc. (A)	GST Amount (B)	Total Cost (A)+(B)
1.	ABC Mono Ammonium Phosphate base powder (manual)	2 kg	1			
2.	ABC Mono Ammonium Phosphate base powder (manual)	4 kg	1			
3.	ABC Mono Ammonium Phosphate base powder (manual)	6 kg	1			
4.	ABC Mono Ammonium Phosphate base powder (Automatic / modular)	5 Kg	1			
5.	CO2 (BC) Type	3.2 kg	1			
6.	CO2 (BC) Type	4.5 Kg	1			

Note

- (1) All fire extinguishers should comply with respective IS 15683:2018.
- (2) All extinguisher should marked with following information:
 - Manufacture's name or Trade Mark
 - Year of Manufacturing of the cylinder and test pressure
 - Method of operation in prominent letters
 - ISI Marking, CE marking

Place:

Date :

Signature of authorized signatory
With Seal

(To be submitted in vendors letter head)