

CO: ESTATE DEPARTMENT.

Annexure

Work: Tender for "PROPOSED EXTERNAL ELEVATION AND CIVIL WORKS OF INDIAN BANK HEAD OFFICE, 66, RAJAJI SALAI, CHENNAI – 600 001".

Reply to the queries raised during Pre-bid meeting held on 14.02.2023 with bidders.

Sno	Query raised by the bidders	Bank's Reply
01	For BOQ – Item No - 12, Perforation holes drawing details and Aluminium section size with detailed drawing required.	<p>Perforation holes drawings are enclosed in annexure along with tender document as sheet no 3 named "Aluminium Perforated sheet".</p> <p>Detailed Drawing of typical section towards fixing / installation of Aluminium section is available in the annexure along with tender document in sheet no 1 named Eastern side HO Elevation (a detailed sectional drawing showing Aluminium frames, Aluminium Perforated Sheets and Corian Cladding is also attached along with this pre-bid clarification).</p> <p>Aluminium Section size are mentioned in the BOQ Item no 12 itself. We are restating the same as follows: "The sheet will be sheared at all corner to hold the aluminium toggle cleat of 50mm depth 19 x 19 x 2 mm thk L angle at a space of 400 mm c/c. The toggle cleat fixed to aluminium sheet using countersunk screws and the total unit fixed to the back frame of 100 mm x 50mm x 2mm thk aluminium box section".</p>
02	Detailed drawing and font sizes with style for Name board.	<p>As per BOQ Item No: 18 Contractor need to supply & install only "Bank Logo" there is no letter to be incorporated in the Name Board.</p> <p>Shop drawing based on reference drawing provided in the annexure along with tender document in sheet no 1 named Eastern side HO Elevation to be provided by the contractor and the same to be submitted to Bank Architect and Indian Bank for approval before fabrication.</p>
03	3D Drawing of External Elevation required.	3D Elevation drawing will be attached along with prebid clarification.
04	In case of CNC work please send us an approved CNC design to	Approved CNC work detailed drawing is enclosed in annexure along with tender





	quote the perforated Sheet & Corian.	document in sheet no 3 named "Aluminium Perforated sheet". Shop drawing based on reference drawing to be provided by the contractor and the same to be submitted to Bank Architect and Indian Bank for approval before fabrication.
05	Details drawing required for corian (solid surface acrylic board) fixing work	Detailed Drawing of typical section towards fixing / installation of Aluminium section & Corian (solid surface acrylic board) Cladding is available in the annexure along with tender document in sheet no 1 named Eastern side HO Elevation (a detailed sectional drawing showing Aluminium frames, Aluminium Perforated Sheets and Corian Cladding is attached along with this prebid clarification).
06	Whether Scaffolding is considered for 120 days only	The Scaffolding rates need to be worked out on SQM basis only, Time frame of 120 days is not considered. Contractor need to quote rate for this item based on SQM basis. The Scaffolding to be in erection till completion of all item of works in project which require scaffolding.
07	Alternate Brands for Terra Cotta Clay Tiles other than NBK Brand	Hunter dogluas, NUVCOTTA
08	Alternate Brands for Corian Cladding (solid surface acrylic board) other than LG	LG, Tristone, Dupont

Corrigendum in reference to the captioned subject:

In, Tender Document Part – 2, Price Bid, Item No: 13 Item description **Shall be read as under:**

S.No	Existing Item Description	Revised Item Description
01	"Providing and fixing of Corian Cladding (Colour: Glacier white) LG Hi macs/ Merino of 12mm thick exterior corian cladding in approved colour and pattern or design as per the elevation".	"Providing and fixing of Corian Exterior Cladding (solid surface acrylic board) (Colour: Glacier white) of 12mm thick exterior corian cladding in approved colour and pattern or design as per the elevation".

Further Bank has also informed that, the tender being an online e-tender, the bidders are advised to plan submission of documents in tender wizard portal well in advance before last date and time of submission. This Pre-Bid clarification sheet has to be signed / sealed and uploaded along with the Technical Bid document.

