

विभाग का नाम Name of the Department	काँ.का: वय्य विभाग ZO : Dharmapuri		
नोट सं. Note No.	ZODHM/INDSETI/2024-25/02	Date/ दिनांक	27.08.2024
.....को नोट Note to.....	ZONAL MANAGER		
विषय/ Subject	Seeking permission to port the queries raised by the bidders in the pre-bid meeting held on 27.08.2024 and replies prepared by the Bank / Architect in our Bank's Web-site for Proposed Construction of G+1 Floors of Indian Bank INDSETI Building at Settikarai, Dharmapuri.		
नोट का स्वभाव Nature of the Note	मंजूरी / अनुमोदन / सूचनार्थ / पुष्टिकरण के लिए Sanction /Approval✓/ Information—/ Ratification		
अनुमोदन / मंजूरी के मामले में अनुमोदन / मंजूरी का स्वभाव (उचित बक्स पर ✓ लगाएं) In case of approval / sanction nature of approval / sanction (Tick appropriate box)	प्रशासनिक Administrative <input checked="" type="checkbox"/>	पूंजी / राजस्व व्यय Capital / Revenue Expenditure <input type="checkbox"/>	
यदि पुनः प्रस्तुतीकरण है, तो पिछले नोट के विवरण If resubmission, details of the previous Note	पिछली नोट सं./ Previous Note No. दिनांक Date: निदेश (यदि हों) Directions (if any):		
नोट का उद्देश्य (संक्षेप में) Purpose of the Note (in brief)	Seeking permission to port the queries raised by the bidders in the pre-bid meeting held on 27.08.2024 and replies prepared by the Bank / Architects in our Bank's Web-site for for Proposed Construction of G+1 Floors of Indian Bank INDSETI Building at Settikarai, Dharmapuri.		
मंजूरी / अनुमोदन प्राधिकारी (बैंक के वर्तमान दिशानिर्देशों के अनुसार - कृपया नीति का नाम / पृष्ठ सं. / पैरा सं. का उल्लेख करें) Sanctioning/Approving Authority (in terms of Bank's extant guidelines - Please state the name of the Policy/ Page No./Para No.)	Zonal Manager The matter involves porting of information pertaining to the subject works in our Bank's web-site. As per IBA guidelines, at every stage of the tendering process, the Dept Head has to be appraised about the developments and his permission has to be sought at various stages. Hence note is placed to the Department Head for approval.		

R. S. G.

Our Bank has initiated tender process towards construction of G+1 floor of Indian Bank INDSETI Building at Settikarai Village, Dharmapuri.

Vide mail dated 16.08.2024 CO: FID had accorded Financial Sanction of Rs. 3,61,32,259/- plus applicable GST ((Rs.3,36,54,450/- as estimate approval + Rs.16,82,722/- as 5% contingency + Rs.7,95,086/- as Consultancy Fee) plus applicable GST).

Advertisements were published in Bank's web-site / portal and in New Indian Express & Dinamani Newspapers on 17.08.2024 & 18.08.2024 respectively.

Pre-bid meeting was held on 27.08.2024, which was attended by 3 no of bidders for Proposed construction of G+1 floor of Indian Bank INDSETI Building at Settikarai Village, Dharmapuri, apart from bidders Executives of CO FID, CO Estate Department and our department officials and members of Bank Architect M/s. Nanda Associates had also attended the meeting.

In this pre-bid meeting, 4 no. of queries were raised by the bidders regarding proposed work for which replies were given from Bank/Architect's side during the meeting.

As per our Bank norms, the queries raised by the bidders and the replies given by Bank/Architect have to be ported in our Bank's web-site for the information of all prospective bidders.

The replies prepared by the Architect are scrutinized by Technical Officer for the project. We are enclosing the details of queries raised during the pre-bid meeting held on 27.08.2024 and replies prepared as annexure for the respective works.

<p>बैंक के नीतिगत दिशानिर्देशों का अनुपालन (संबंधित नीति का नाम / पृष्ठ सं. / पैरा) Compliance of Policy guidelines of the Bank (relevant Name / Page No./ Para of the Policy)</p>	<p>Bank's extant Policy & works procurement manual has been complied.</p>
<p>सीवीसी / भारिबैंक / भारत सरकार के दिशानिर्देश, यदि हों, का अनुपालन (कृपया संबंधित दिशानिर्देशों का उल्लेख करें) Compliance of CVC / RBI / GOI guidelines, if any (please specify the relative guidelines)</p>	<p>Yes – will be complied</p>
<p>क्या दिशानिर्देशों की अपेक्षाओं के अनुसार किसी समिति / मंजूरी प्राधिकारी से अनुमोदन / संस्तुति प्राप्त की गई है। कृपया समिति / मंजूरी प्राधिकारी के नाम, दिनांक, निदेशों आदि के विवरण दें। Whether approval / recommendation obtained from any Committee / Sanctioning Authority, if required as per guidelines. Please give details like name of the Committee/SA, date, directions, etc.</p>	<p>Vide departmental note dated 17.08.2024, Competent Authority has accorded administrative approval towards floating the tender document in Banks website and Tender wizard portal.</p>

R. D. J.

विभाग की संस्तुति तथा समर्थन प्रस्तुत करें / Recommendation along with justification of the Department:

In view of the above, we seek permission to port the queries raised by the bidders in the pre-bid meeting held on 27.08.2024 and replies prepared by the Bank/Architect in our Bank's Web-site for Proposed construction of G+1 floor of Indian Bank INDSETI Building at Settikarai Village, Dharmapuri.

Placed for approval.


SENIOR MANAGER (CIVIL)


Manager (Premises)


CHIEF MANAGER (Premises)


DEPUTY ZONAL MANAGER


ZONAL MANAGER



ZO: Dharmapuri.

Annexure

Work: Tender for "Proposed Construction of G+1 Floor INDIAN Bank INDESETI Building at Settikarai Village, Dharmapuri".
Reply to the queries asked through e-mail and during Prebid meeting held on 27.08.2024 of bidders.

S. no	Tender Clause / Item No	Description as per Tender document	Query raised by the bidders	Bank's Reply
01	In Technical Bid clause no:11 of Note in page No:11	"As per extant guidelines, there is no exemption for Companies registered with Micro, Small & Medium Enterprises or NSIC, Hence all the bidders need to submit EMD".	Whether exemption is allowed for MSME or NSIC company?	As Per Extant guideline, No Exemption of EMD is applicable for MSME or NSIC company applying for Work Contract. Hence tender clause holds good. All the Bidders need to submit specified EMD amount.
02	In Technical Bid clause no:4.5 of Informations and Instructions to tenderer in page No:35	It shall be the responsibility of the contractor to arrange for water and electricity required for completing construction. In case, there is suitable water (Tested through Laboratory) available for construction purpose at site, the same shall be utilized by the contractor at One Point. The contractor will have to make arrangement of pipeline for distributing water. In case there is no suitable water available /not adequate supply of water at site, the Contractor has to make own arrangement for procurement/ supply water (Good/Suitable for Construction as per IS) through other sources, at their cost. No additional cost shall be payable to the Contractor (Cost & Time).	Is arrangement of Water under the scope of contractor.	Yes, it shall be the responsibility of the contractor to arrange for water and electricity required for completing construction as per tender clause no: 4.5 of Informations and Instructions to tenderer in page No:35.
03	In Technical Bid clause no:79.2 of Informations and	If required by the employer/ Architects the Tenderer shall have to carry out tests on materials and workmanship in approved	Whether all materials proposed to be used at site need to be	Yes all materials proposed to be used at site need to be tested in any of the



ZO: Dharmapuri.

<p>Instructions to tenderer in page No:78</p>	<p>materials testing laboratories or as prescribed by the employer/Architects at his own cost to prove that the materials etc. Under test conform to the relevant I.S. Standards or as specified in the specifications. The necessary charges for preparation of mould (in case of concrete cube) transporting, testing etc., shall have to be borne by the Tenderer. No extra payment on this account should in any case be entertained.</p>	<p>tested?</p>	<p>NABC/NCB certified laboratories and to be used only after production of test certificates.</p>
<p>04 In Financial Bid: Item No:101</p>	<p>Supply and fixing in position best quality PVC IS 4985 - CLASS-II - 4 Kg/ Sqcm -Rain water pipes of various size having ISI mark and providing leak proof joints with such as Bend, Tee Junction, door etc., of approved quality including fixing to the wall with special PVC /MS clamps, etc., and making connection to all sanitary fittings, wherever necessary and making chipping good to the original condition, complying with standard specification etc., complete.</p>	<p>Whether item rate include rates for joints, elbow, tee and other special fitting?</p>	<p>The bidders are advised to quote the rate of Rain water pipe including the rate of special fittings & accessories and labour etc., necessary for proper completion of work.</p>

Bidders please note :

- 1) All bidders are requested to download this sheet and upload the same along with other documents duly stamped and signed.

