



Zonal Office Tiruppur  
2<sup>nd</sup> Floor KRBS Towers PN Road Tiruppur  
Email: ZOTiruppur@indianbank.co.in

## NOTICE INVITING QUOTATION

Indian Bank, Zonal Office Tiruppur invites sealed quotes for procurement of Electrical Fixtures for the proposed space for setting up MCB Namakkal Branch at 119 B Aarthi Complex Salem Road, Namakkal.

Quotation document may be downloaded from Indian Bank website from 30.01.2025.

RFQ Issue date : 30.01.2025  
RFQ Closing date : 03.02.2025 12.00 PM



  
Zonal Manager

S.No	Description	Unit	QTY	Rate	Amount
A	<p><b>Supply of the following MAIN DB (8WAY VTPN DB)</b></p> <p>ThreePhase Vertical Distribution board with neutral bar, earth bar, cables ties, top and bottom removable gland plate and with necessary adopter boxes if any. The DB should be IP42 metallic double door with provision of MCB etc as Required including cutting of wall and plastering the same with neat finish. It comprising as follows:-</p> <p>Incomer :</p> <p>100A TPN MCCB-1Nos</p> <p>Outgoings:</p> <p>63A TP MCB-4Nos</p> <p>32/25/20A SP MCBs-5Nos</p>	Set	1		
B	<p><b>Supply of the following LIGHTING DB (4 WAY TPN DB)</b></p> <p>Three Phase, Phase Segregated Distribution board with neutral bar, earth bar, cables ties, top and bottom removable gland plate and with necessary adopter boxes if any. The DB should be IP42 metallic double door with provision of MCB etc as required including cutting of wall and plastering the same with neat finish. It comprising as follows:-</p> <p>Incomer : 40A TPN MCB</p> <p>Outgoings:</p> <p>10/6A SP MCBs-12Nos</p>	Set	1		
1	<p><b>POWER DB (4 WAY TPN DB)</b></p> <p>Three Phase, Phase Segregated Distribution board with neutral bar, earth bar, cables ties, top and bottom removable gland plate and with necessary adopter boxes if any. The DB should be IP42 metallic double door with provision of MCB &amp; ELCB etc as required including cutting of wall and plastering the same with neat finish. It comprising as follows:- Incomer : 63A TPN MCB</p> <p>Outgoings:</p> <p>32/25/20A SP MCBs-12Nos</p>	Set	1		
2	<p><b>COMPUTER DB (8 WAY SPN DB)</b></p> <p>12 Way SPN Distribution board with neutral bar, earth bar, cables ties, top and bottom removable gland plate and with necessary Adopter boxes if any. The DB should be IP42 metallic double door with provision of MCB &amp; ELCB etc as required including cutting of wall and plastering the same with neat finish. It comprising as follows:-</p> <p>Incomer : 40A DP MCB</p> <p>Outgoings:</p> <p>10A SP MCBs-6Nos</p>	Set	2		
3	Supply of the following with the necessary enclosure and adopter boxes if necessary,				

	a)63ATPNMCB	Set	2		
	b)63ADPMC	Set	4		
4	Supply of 32A Metal Clad Socket with top in a specified company manufactured box with suitable rating MCB for AIR CONDITIONS	set	5		
5	Supply of 63A 4Pole Change over switch set of 3 nos.	set	1		
6	Supply and Fixing for 63A Phase Selector switch with enclosure and adopter boxes if necessary,	set	2		
7	<b>LIGHTING FIXTURES</b> Supply of Recess mounting type compact vertical Flat Panel 34W LED (2 X 2) fitting in Down Rods with white finish and other fixing accessories. <b>(Crompton, Wipro, Philips)</b>	set	21		
8	Supply, of Recess mounting type compact vertical round shaped 1x15 WLED down lighter fitting with white finish and other fixing accessories., <b>(Crompton, Wipro, Philips)</b>	set	12		
9	Supply of Patti Type LED 20Watts Fittings <b>(Crompton, Wipro, Philips)</b>	Set	8		
10	Supply of exhaust fan <b>(Crompton, Almonard)</b>	set	3		
11	Supply of wall mounting Metal fan with necessary Down Rod sand with all fixing accessories., <b>(Crompton/Havells)</b>	Set	11		
12	Supply of 48"ceiling fan with necessary Down Rod sand with all fixing accessories., <b>(Crompton/ Havells)</b>	Set	3		